



Project:	Comments:	Type:
Catalog No:	Prepared by:	Date:

14101AR Remodel Airtight Housing



INSULATION MUST BE KEPT A MINIMUM OF 3" FROM HOUSING



DESCRIPTION

Suitable for new construction in residential and commercial applications.

NON-IC. Insulation must be kept a minimum of 3" from housing.

HOUSING

Washington State Energy Code approved to meet restricted airflow requirements.

Airtight housing limits the exchange of air between ceiling plenum and heated/cooled areas.

Transformer includes integral thermal protector guards against improper lamping and misuse of insulation materials.

Use low voltage 20W - 50W MR-16 or

JC type lamps (12V).

Class H 50W transformer, step down from 120V to 12V.

Use dimmers specifically designed for low voltage magnetic transformers.

5 1/2" height allows use in 2" x 6" joist construction.

JUNCTION BOX

Listed for through branch circuit wiring and includes several 3/4" knockouts.

Supplied with three push-in wire connectors.

LISTINGS

UL damp location.

UL feed-through.

CUL approved.

